

TABLE 14-1A
UNITARY AIR CONDITIONERS AND CONDENSING UNITS, ELECTRICALLY OPERATED,
MINIMUM EFFICIENCY REQUIREMENTS

Equipment Type	Size Category	Sub-Category or Rating Condition	Minimum Efficiency ^b	Test Procedure ^a
Air Conditioners, Air Cooled	< 65,000 Btu/h ^d	Split System	13.0 SEER	ARI 210/240
		Single Package	13.0 SEER	
	≥65,000 Btu/h and < 135,000 Btu/h	Split System and Single Package	10.3 EER ^c 10.6 IPLV ^c	
		On or After Jan 1, 2010 ^e	11.2 EER ^c	ARI 340/360
	≥135,000 Btu/h and < 240,000 Btu/h	Split System and Single Package	9.7 EER ^c 9.9 IPLV ^c	
		On or After Jan 1, 2010 ^e	11.0 EER ^c	
	≥ 240,000 Btu/h and <760,000 Btu/h	Split System and Single Package	9.5 EER ^c 9.7 IPLV ^c	
		On or After Jan 1, 2010 ^e	10.0 EER ^c	
Through-the-Wall, Air Cooled	<30,000 Btu/h ^d	Split System	10.9 SEER	ARI 210/240
		On or After Jan 23, 2010 ^e	12.0 SEER	
		Single Package	10.6 SEER	
		On or After Jan 23, 2010 ^e	12.0 SEER	
Air Conditioners, Water and Evaporatively Cooled	< 65,000 Btu/h	Split System and Single Package	12.1 EER 11.2 IPLV	ARI 210/240
	≥ 65,000 Btu/h and < 135,000 Btu/h	Split System and Single Package	11.5 EER ^c 10.6 IPLV ^c	
	≥135,000 Btu/h and ≤240,000 Btu/h	Split System and Single Package	11.0 EER ^c 10.3 IPLV ^c	ARI 340/360
	> 240,000 Btu/h	Split System and Single Package	11.0 EER ^c 10.3 IPLV ^c	
Condensing Units, Air Cooled	≥135,000 Btu/h		10.1 EER 11.2 IPLV	ARI 365
Condensing Units, Water or Evaporatively Cooled	≥135,000 Btu/h		13.1 EER 13.1 IPLV	

^a Reserved.

^b IPLVs are only applicable to equipment with capacity modulation.

^c Deduct 0.2 from the required EERs and IPLVs for units with a heating section other than electric resistance heat.

^d Applies to all units, including single-phase and three-phase. For single-phase air cooled air-conditioners < 65,000 Btu/h, SEER values are those set by NAECA.

^e Date of manufacture as regulated by NAECA.